

VS/VS/689

**STATEMENT ACCOMPANY  
FORM - A**

1. Name of the Building : **ANGAPPA EDUCATIONAL TRUST  
SENIOR SECONDARY SCHOOL.**
2. Door No. of the building, Location : S.F.NO:365, Site No: 3  
(Street, Ward No, Name of place, Corporation, Municipality, Panchayat Union/Panchayat/ Town Chip Cantonment) : Raja Annamalai Road, Saibaba Colony, Sanganur Village, Coimbatore Taluk, Coimbatore District.
3. Year of Construction : 1975, 2000, 2005.
4. Approximate cost of construction As per current rates : Rs. 1, 08, 65, 400/-
5. Purpose for which the building is Being Used Or Proposed To Be Used : School Building, Class Rooms, Staff Room, Office, Lab & Toilet.

6. Total built up area of the building

S.NO	DESCRIPTION	AREA in SQ.FT
1	Area Of Block A	8550
2	Area Of Block B	6972
	TOTAL	15,522.

7. Details of construction of the Building (particulars of the Foundation, soil, specification Of the various parts under)

- (a) Foundation : R.C.C Isolated Column Footing & Brick Basement
- (b) Basement : RR Stone Masonry.
- (c) Super structure : Brick Work Framed Structure slabs are in 1:2:4.
- (d) Floor and Roof are to be given : Vitrified Tile Flooring & RCC Roof Slab.

8. No. of persons to be accommodated : 700 persons

Place: Coimbatore  
Date: 27/05/2017

*Dayal*  
**Correspondent**  
Angappa Educational Trust  
Senior Secondary School  
Coimbatore - 641011

*Chand*  
**Principal**  
Angappa Educational Trust  
Senior Secondary School  
Coimbatore-641 011

*N. Raghuraman*  
**CHARTERED ENGINEER**

**NRRAGHURAM & CO**  
AN ISO 9001:2008 CERTIFIED COMPANY ENGINEERS & VALUERS  
**N. RAGHURAMAN**, M.E.(Struct), MSc(REV), FIV, MIE, MISSE, MISTE, MITT(Arb)  
Registered Valuer No:1/2013-2014, Approved Valuer No:F16406  
Civil Engineer. No:M-147258-5, Technical Arbitrator:M-001-092  
Licensed Building Surveyor No:25/Gr.I, Class-1 Panel Engineer No:1/2013  
"Arayan Niwas" 17/1, MKP Colony  
Main Street, Coimbatore

ORIGINAL

**FORM - B**

(Form of Certificate of structural soundness under sub-section (4) of Section 4 of the Tamilnadu Public Building (Licensing) Act, 1965 (Tamilnadu Act 13 of 1965) referred to in rule 4 of the Tamilnadu Public Building (Licensing) Rules 1966).

1. FOUNDATION:

- a) Depth below ground level : 8'0"
- b) Nature of soil met with at Foundation level : Hard Gravel
- c) Pressure at foundation : 40 tons/ Sq.m
- d) Probable safe bearing capacity of The soil met with at foundation : 27 tons/ Sq.m

2. SUPER STRUCTURE:

**RCC Building**

- a) Maximum stress in the most critical Section of masonry and concrete : RCC columns  
Beams & Brick Walls
- b) Nature of masonry and concrete and It's safe permissible stress : Tile Floor/ R.C.C Roof  
Slab Concrete

The building has been designed to take seismic forces and other loads as per relevant

Indian Standards Codes

Place: Coimbatore

Date: 27/05/2017

*Diary*

**Correspondent**  
Angappa Educational Trust  
Senior Secondary School  
Coimbatore - 641011

*Ch*

**Principal**  
Angappa Educational Trust  
Senior Secondary School  
Coimbatore-641 011

*N. Raghuraman*

**CHARTERED ENGINEER**  
**NRRAGHURAM & CO**  
AN ISO 9001:2015 CERTIFIED COMPANY ENGINEERS & VALUERS  
N. RAGHURAMAN, ME (Struct), MS (REV), FIV, MIE, MISSE, MISTE, MNT (Arb)  
Registered Valuer No: 1/2013-2014, Approved Valuer No: F16406  
Chartered Civil Engineer, No: M-147258-S, Technical Arbitrator: M-001-092  
Licensed Building Surveyor No: 25/Gr.I, Class-1 Panel Engineer No: 1/2013  
"Narayan Niwas" 17 / 1, MKP Colony  
Main Street, Ganapathy, Coimbatore - 641 006  
Phone / Cell : 0422 - 2533891, 97877 15858  
Email / Website : nrraghuram@gmail.com / www.nrraghuramco.com  
Mobile : 98420 15858, 98438 15858

ORIGINAL

**FORM - C**

(Form of Certificate of structural soundness under sub-section (4) of Section 4 of the Tamilnadu Public Building (Licensing) Act, 1965 (Tamilnadu Act 1965) referred to in rule 4 of the Tamilnadu Public Building (Licensing) Rules 1966)

Location of the building. Door No., Street and Name of the place	Age of the building	Total Value of the building at the current rate	Short description of structure – steel-RCC framed of load bearing masonry	Purpose for which the building is certified for use	The Period for which the building will be structural soundness	No. of persons to be accommodated	Remarks
Angappa Education Trust, Senior Secondary School. S.E.No:365, Site No: 3, Raja Annamalai Road, Saibaba Colony, Sangapur Village, Coimbatore District.	Existing Building RCC 2001-16 Yrs	Rs.1,08,65,400/-	75 tons/m <sup>2</sup>	School Building	27.05.2017 To 26.05.2022	700 Persons	NIL


Place: Coimbatore

Date: 27/05/2017

*Deepa*  
**Correspondent**  
Angappa Educational Trust  
Senior Secondary School  
Coimbatore - 641011

*Deepa*  
**Principal**  
Angappa Educational Trust  
Senior Secondary School  
Coimbatore-641 011

*Nirakshar*  
**CHARTERED ENGINEER**  
**NRRAGHURAM & CO**  
AN ISO 9001:2015 CERTIFIED COMPANY ENGINEERS & VALUERS  
**N. RAGHURAMAN**, ME (Struct), MS (REV), FIV, MIE, MISE, MISTE, MITT (Arb)  
Registered Valuer No:1/2013-2014, Approved Valuer No:F16406  
Chartered Civil Engineer. No:M-147258-5, Technical Arbitrator:M-001-092  
Licensed Building Surveyor No:25/Gr.I, Class-1 Panel Engineer No:1/2013  
"Narayan Niwas" 17 / 1, MKP Colony  
Main Street, Ganapathy, Coimbatore - 641 006  
Phone / Cell : 0422 - 2533891, 97877 15858  
Email / Website: nrraghuram@gmail.com / www.nrraghuramco.com  
Mobile : 98420 15858, 98438 15858



**RAIN WATER HARVESTING REPORT**

This is to certify that **ANGAPPA EDUCATIONAL TRUST SENIOR SECONDARY SCHOOL.**

S.F.NO:365, Site No: 3, Raja Annamalai Road, Saibaba Colony, Sangapur Village, Coimbatore Taluk, Coimbatore – 641 027.

The Rain Water which is collected from roof top is taken safely to the ground pits

Through PVC pipes. Each block contains five percolation pits of size 1'0"x1'0"x10'0"

The water is taken to percolation pits by 2" PVC pipes.

**Percolation Pit**

Percolation pit consists of size 1'0"x1'0"x10'0" which is filled by broken brick Jelly and top layer is filled by river sand.

The water percolates through the percolation pits gets filtered by river sand and Brick jelly and the water enter into earth and increase the water level.

Place: Coimbatore

Date: 27/05/2017

*Dayal*  
**Correspondent**  
Angappa Educational Trust  
Senior Secondary School  
Coimbatore - 641011

*Chand*  
**Principal**






**Angappa Educational Trust  
Senior Secondary School  
Coimbatore-641 011**

*N. Raghuraman*  
**CHARTERED ENGINEER**

**NRRAGHURAM & CO**  
AN ISO 9001:2015 CERTIFIED COMPANY ENGINEERS & VALUERS

**N. RAGHURAMAN**, ME (Struct), MSc (REV), FIV, MIE, MISSE, MISTE, MITT (Arb)  
Registered Valuer No:1/2013-2014, Approved Valuer No:F16406  
Chartered Civil Engineer. No:M-147258-5, Technical Arbitrator:M-001-092  
Licensed Building Surveyor No:25/Gr.I, Class-1 Panel Engineer No:1/2013  
"Narayan Niwas" 17 / 1, MKP Colony  
Main Street, Ganapathy, Coimbatore - 641 006  
Phone / Cell : 0422 - 2533891, 97877 15858  
Email / Website : nrraghuram@gmail.com / www.nrraghuramco.com  
Mobile : 98420 15858, 98438 15858

ORIGINAL



*Dayd*

**Correspondent**

Angappa Educational Trust  
Senior Secondary School  
Coimbatore - 641 011




*Chand*

**Principal**  
Angappa Educational Trust  
Senior Secondary School  
Coimbatore-641 011

# ORIGINAL NRRAGHURAM & CO

AN ISO 9001:2015 CERTIFIED COMPANY ENGINEERS & VALUERS

Proprietor: **N. RAGHURAMAN**, ME.(Struct), MSc (REV), FIV, MRICS, MIE., MISSE, MISTE, MIIT (Arb)



ISO 9001



Registered Valuers, ( Wealth Tax Valuers ), Bank Approved Valuers,  
Chartered Civil Engineers, Class 1A Panel Engineers,  
Consulting Civil Engineers, L B S (Grade I), Technical Arbitrators



Decide with Confidence



## DECLARATION

I, Mr. N. RAGHURAMAN, ME.(Struct), Msc.,(REV), FIV., AMIE., MISTE, MIIT(Arb)  
S/o. S. Narayana Rao, Residing at 15 & 16, MKP Colony, Main Street, Ganapathy,  
Coimbatore, do hereby I possess the qualification and experience specified in  
the Table Rule II of the Madras Public Building (Licensing) rules 1966 for issuing  
the certificates of structural soundness of the building covered by the certificate.

Place: Coimbatore.

Date: 27/05/2017

*N. Raghuraman*

**CHARTERED ENGINEER**

AN ISO 9001:2015 CERTIFIED COMPANY, ENGINEERS & VALUERS

**N. RAGHURAMAN**, ME.(Struct), MSc.(REV), FIV, MIE., MISSE, MISTE, MIIT(Arb)  
Registered Valuer No:1/2013-2014, Approved Valuer No:F16406  
Chartered Civil Engineer. No:M-147258-5, Technical Arbitrator:M-001-092  
Licensed Building Surveyor No:25/Gr.I, Class-1 Panel Engineer No:1/2013  
"Narayan Niwas" 17 / 1, MKP Colony  
Main Street, Ganapathy, Coimbatore - 641 006  
Cell : 98426 15858, 98438 15858  
E-mail : nrraghuram@gmail.com / www.nrraghuramco.com

1. Name and Address : N. Raghuraman ME, FIV, AMIE, MISTE  
16&17, MKP Colony  
Main Street, Ganapathy,  
Coimbatore.
2. Engineer Qualification : ME., (Struct), Msc, (REV), FIV., AMIE.,  
MISTE, MIIT (Arb)
3. Experience : 22 Years

*Daght*  
**Correspondent**

Angappa Educational Trust  
Senior Secondary School  
Coimbatore - 641011


*Chand*  
**Principal**

Angappa Educational Trust  
Senior Secondary School  
Coimbatore-641 011

Off : " Narayan Niwas " D.No. 17-1, 1st Floor, MKP Colony, Main Street, Ganapathy, Coimbatore - 641 006.

Office Ph : 0422 2533891, Cell : 97877 15858, 90430 15859, 99431 44988


Website : www.nrraghuramco.com



ORIGINAL

# NR RAGHURAM & CO

AN ISO 9001:2015 CERTIFIED COMPANY ENGINEERS & VALUERS



Proprietor: **N. RAGHURAMAN**, ME.(Struct), MSc (REV), FIV., MRICS, MIE., MISSE, MISTE, MIIT (Arb)



Registered Valuers, ( Wealth Tax Valuers ), Bank Approved Valuers,  
Chartered Civil Engineers, Class 1A Panel Engineers,  
Consulting Civil Engineers, L B S (Grade I), Technical Arbitrators



## DECLARATION

I, Mr. N. RAGHURAMAN, ME.(Struct), Msc.,(REV), FIV., AMIE., MISTE, MIIT(Arb)  
S/o. S. NarayanaRao, Residing at 15 &16, MKP Colony, Main Street, Ganapathy,  
Coimbatore, do hereby I possess the qualification and experience specified in  
the Table Rule II of the Madras Public Building (Licensing) rules 1966 for issuing  
the certificates of structural soundness of the building covered by the certificate.

Place: Coimbatore.  
Date: 27/05/2017

*N. Raghuraman*  
**CHARTERED ENGINEER**  
AN ISO 9001:2015 CERTIFIED COMPANY ENGINEERS & VALUERS  
**N. RAGHURAMAN**, ME.(Struct), MSc (REV), FIV., MIE., MISSE, MISTE, MIIT(Arb)  
Registered Valuer No:1/2013-2014, Approved Valuer No:F16406  
Chartered Civil Engineer. No:IA-147258-5, Technical Arbitrator:M-001-092  
Licensed Building Surveyor No:25/Gr.I, Class-1 Panel Engineer No:1/2013  
'Narayan Niwas' 17 / 1, MKP Colony  
Main Street, Ganapathy, Coimbatore - 641 006  
Mobile: 98420 15858, 98430 15358  
E-mail: nrraghuram@gmail.com / www.nrraghuramco.com

- 1. Name and Address : N. Raghuraman ME, FIV, AMIE, MISTE  
16&17, MKP Colony  
Main Street, Ganapathy,  
Coimbatore.
- 2. Engineer Qualification : ME., (Struct), Msc, (REV), FIV., AMIE.,  
MISTE, MIIT (Arb)
- 3. Experience : 22 Years

*Durga*  
**Correspondent**  
Angappa Educational Trust  
Senior Secondary School  
Coimbatore - 641011

*Chand*  
**Principal**  
Angappa Educational Trust  
Senior Secondary School  
Coimbatore-641 011

